


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Circuit-breakers for overcurrent protection
Name and address of the applicant	Wenzhou Huajia Electrical Equipment Co., Ltd. No. 311, Latitude Fifteen Road, Yueqing Economic Development Zone, Zhejiang, China
Name and address of the manufacturer	Same as applicant
Name and address of the factory Note: When more than one factory, please report on page 2	Same as applicant
Ratings and principal characteristics	Ue= 230V/400V~(1P), 400V~(230V~)(2P), 400V~(3P, 4P) In= 6, 10, 16, 20, 25, 32, 40, 50, 63A Ics=Icn=6000A, B- and C- type, Energy limiting class 3 (6-32A)
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	SGP
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60898-1:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	180801235SHA-001, 180801235SHA-002, 180801235SHA-003, 180801235SHA-004


This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 19 September 2018

intertek

Signature:


Bo Berglöf



Total Quality. Assured.

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista
Sweden

Tel +46 8 750 00 00
info-sweden@intertek.com
intertek.se

Intertek Testing Services Ltd, Shanghai #64
Building B7. No. 51
1089 Qinzhou Road (North)
Caohejing Development Zone
Shanghai 200233

CHINA

Handled by
Maarit Franzén
Reference
1815818
E-mail
maarit.franzen@intertek.com
Your reference
Cherry Wang

19 September 2018

CB-certificate(s) SE-91948

We have the pleasure to enclose the requested CB-certificate(s) and the pertaining Test Report.

Yours sincerely

Intertek Semko AB
Product Certification

Enclosure CB certificate(s)

