

IEC

IECEE
CB
SCHEME

Ref. Certif. No.

HU-002116

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit breaker for overcurrent protection

Name and address of the applicant

WENZHOU HUAJIA ELECTRICAL EQUIPMENT CO., LTD.
NO.311, LATITUDE FIFTEEN ROAD, YUEQING ECONOMIC
DEVELOPMENT ZONE, ZHEJIANG, CHINA

Name and address of the manufacturer

WENZHOU HUAJIA ELECTRICAL EQUIPMENT CO., LTD.
NO.311, LATITUDE FIFTEEN ROAD, YUEQING ECONOMIC
DEVELOPMENT ZONE, ZHEJIANG, CHINA

Name and address of the factory

WENZHOU HUAJIA ELECTRICAL EQUIPMENT CO., LTD.
NO.311, LATITUDE FIFTEEN ROAD, YUEQING ECONOMIC
DEVELOPMENT ZONE, ZHEJIANG, CHINA

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ue = 230/400V ~ (1P), 400V ~ (2P/3P/4P); B/C-type;
In = 1A, 2A, 4A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;
Icn=Ics=3kA

Trademark (if any))

TEXENERGO

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

HEA2

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

1W170276-B1

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Date: 2017-12-11

Signature:

Gabor Kassai
Gabor Kassai

